



Addendum #1

April 27, 2022

To: All Plan Holders
From: St. John Engineering, LLC
Owner: City of Manchester, TN
Project: 102-159.04 Manchester Farmer's Market Building Electrical Package
Bid Date: April 29, 2022, 10:00 a.m. (unchanged)

This addendum consists of 1 page.

Acknowledge receipt of this addendum in the space provided on the Bid Form.

1) Reference: None

Inquiry: Per drawing ES1.1 the disconnect transformer and panel will be located on the far side of the building from the PP panel the power is being pulled from. Would it be possible to move this location or the disconnect location?

Clarification: The transformer and panel should be in the location indicated on the drawings. The disconnect switch may be located on the exterior of the building at a location that is closer to the 'PP' panel but is still mounted on the new building. The rating of the disconnect switch would need to change to be NEMA 3R. Final location of disconnect switch shall be determined in the field with the Owner.



End of Document